


NOTE: FOR COMMERCIAL RECLAIMED WATER INSTALLATION ONLY IF CHEMICALS ARE NOT ADDED TO THE CUSTOMER'S SYSTEM.


MATERIALS		
ITEM	QTY.	DESCRIPTION
1	1	AMI TURBINE RECLAIMED WATER METER
2	2	90 DEGREE ELBOW D.I.P. - FLANGE TO FLANGE
3	2	GATE VALVE C.I. (OS&Y)
4	1	STRAINER - FLANGE TO FLANGE
5	2	ADJUSTABLE PIPE SUPPORTS
6	*	4" CONCRETE SLAB
7	2	RISERS - D.I.P. - FLANGE TO FLANGE ORDER TO FIT
8	2	90 DEGREE ELBOW, D.I.P. - FLANGE TO MJ
9	2	MEGALUG RETAINER GLANDS
10	1	PIPE TRACER WIRE ASSEMBLY - SEE DETAIL "A"



NOTES:

- ORDER TO FIT ITEM #7 TO PROPER LENGTH.
- ALL FITTINGS ABOVE GROUND SHALL BE FLANGED.
- ALL PIPE SUPPORTS SHALL BE ADJUSTABLE.
- CONCRETE SLAB SHALL BE 4" THICK AND EXTEND 12" MINIMUM AROUND ENTIRE INSTALLATION IN ALL DIRECTIONS.
- BOLLARDS AS REQUIRED IN HIGH TRAFFIC AREAS, PAINTED OSHA APPROVED SAFETY YELLOW.
- PIPE AND FITTINGS TO BE PAINTED: PANTONE PURPLE

City of Plant City
1802 Spooner Drive
Plant City, FL 33563
Phone: (813) 757-9288



AMI TURBINE RECLAIMED WATER METER
INSTALLATION SINGLE SERVICE
3" TO 10" RECLAIMED WATER SERVICE

DRAWING NO.

ORIGINAL DRAWING 10/03/2017

SCALE: NTS

RS-4

REVISION DATE

PAGE NO.

REVISION DATE

50

REVISION DATE